



**REQUEST FOR PROPOSALS
(RFP) # FY 2018-2019-008**


**CITY OF HALLANDALE BEACH WATER TREATMENT PLANT
REPLACEMENT OF DEGASIFIER PACKING MEDIA**

EXHIBIT A – DEGASIFIER MEDIA SHEET

**PREPARED BY:
CITY OF HALLANDALE BEACH
DEPARTMENT OF PUBLIC WORKS
AND
PROCUREMENT DEPARTMENT**

Jaeger Tri-Packs®

High-performance, free-flowing random spherical packing for scrubber and stripper applications. NSF certified or listed for potable water contact.



Size		1"	2"	3.5"
Geometric Surface Area	ft ² /ft ³	85	48	38
Packing Factor	1/ft	28	16	12
Void Space	%	90.0	93.5	95.0
Bulk Density (reference: polypropylene)	lb _m /ft ³	6.2	4.2	3.3

Jaeger Tri-Packs® (all sizes) are National Sanitation Foundation (NSF) certified or listed for potable water contact. No reground or recycled plastic resin is used to mold Jaeger Tri-Packs ®. Only virgin resin direct from a primary supplier is used. This assures that the rigid requirements of NSF including passing unannounced audits of our production facility are assured. A customer can purchase product in complete confidence that the integrity of their drinking water will be assured.

For more information and design assistance, please contact us at:

Raschig USA, Inc.
Formerly Raschig Jaeger Technologies
 2201 E. Lamar Blvd. #240
 Arlington, TX 76006
 800-678-0345
 817-695-5680
 info@raschig-usa.com

Jaeger Tri-Packs® is a Registered Trademark of Raschig USA, Inc.

IMPORTANT: The following supercedes Buyer's Documents. SELLER MAKES NO REPRESENTATION OR WARRANTY, EXPRESS OR IMPLIED, INCLUDING OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. No statements herein are to be construed as inducements to infringe any relevant patent. Under no circumstances shall Seller be liable for incidental, consequential or indirect damages for alleged negligence, breach of warranty, strict liability, tort or contract arising in connection with the product(s). Buyer's sole remedy and Seller's sole liability for any claims shall be Buyer's purchase price. Data and results are based on controlled or lab work and must be confirmed by Buyer by testing for intended conditions of use. The product(s) has not been tested for, and is therefore not recommended for, uses for which prolonged contact with mucous membranes, abraded skin, or blood is intended; or for uses for which implantation within the human body is intended.