

## ADDENDUM # 1 BID # FY 2021-2022-021 LIFT STATION # 2 REHABILITATION

## **REVISED EXHIBIT A**

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: <a href="https://www.cohb.org\solicitations">www.cohb.org\solicitations</a>.

## PLEASE NOTE: REVISED Exhibit A, Page E-03

Please insert the following Note #3 onto Page E-03 of EXHIBIT A - DESIGN DRAWINGS.

Base Flood Elevation (BFE) is 6.0' NAVD 1988.

The bottom of all electrical equipment shown on this sheet and the bottom of the generator enclosure shall be installed at a minimum of 12 inches above the BFE. Pump station electrical controls and equipment must be protected from physical damage by the 100-year flood. The height of the generator platforms should be based on the base flood elevation of 6.0' NAVD as shown on Note #4 on the Proposed Site Plans. The platform and stair dimensions should be provided by the generator vendor.

## PLEASE NOTE RECEIPT OF ADDENDUM # 1 BY COMPLETING 'FORM P: ACKNOWLEDGEMENT OF ADDENDA' WITH YOUR FIRM'S SUBMISSION.

Code of Ordinances, Chapter 23 Procurement, Section 23-14 Cone of Silence – imposes a Cone of Silence for City purchases of goods and services. The Cone of Silence means prohibition on any communication regarding a particular RFP, RFQ, ITB, RFLI, or any other advertised solicitation between a potential proposer, offeror, respondent, bidder, lobbyist or consultant and the city's staff including, but not limited to, the city manager and his/her staff; the evaluation/selection committee; the mayor; and the city commission and their respective staff. The Cone of Silence shall be imposed when a formal competitive solicitation has been issued and shall remain in effect until an award is made, a contract is approved, or the Commission/Board of Directors takes any other action which ends the solicitation. Should any firm contact you, please direct the communication to the Procurement Department at (954) 457-1333.