



ADDENDUM # 6
BID # FY 2022-2023-002
LIFT STATION # 1 IMPROVEMENTS

ADDITIONAL QUESTIONS AND ANSWERS

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: www.cohb.org\solicitations.

QUESTION 1. What is specified and what is shown on the drawings are two different things. For starters, what's shown on the detail is a 1" valve. The smallest inlet size available from any manufacturer on a sewage air release valve is 2". The drawing calls for a pressure air release valve with a vacuum check. The spec. calls for a dual body combination sewage air release valve assembly with backflushing attachments, and also air & vacuum and pressure air release valves separately. The drawing calls for a 1/16" air release orifice. The spec. calls for a 3/8" orifice.

ANSWER 1: Please see Addendum # 5. We have revised the drawing to reflect a minimum 2" NPT connection and sized the combination ARV offices for the flow conditions as follows: The (3) 12" pump discharge lines ARV will require a 5/16" orifice for the 2,600 gpm pump discharge flow rate. The force mains larger ARV will require the combination ARV to be sized for 7,800 gpm flow rate with a minimum 1/2" orifice.

PLEASE NOTE RECEIPT OF ADDENDUM # 6 BY COMPLETING 'FORM P: ACKNOWLEDGEMENT OF ADDENDA' WITH YOUR FIRM'S SUBMISSION.

Code of Ordinances, Chapter 23 Procurement, Section 23-14 Cone of Silence – imposes a Cone of Silence for City purchases of goods and services. The Cone of Silence means prohibition on any communication regarding a particular RFP, RFQ, ITB, RFLI, or any other advertised solicitation between a potential proposer, offeror, respondent, bidder, lobbyist or consultant and the city's staff including, but not limited to, the city manager and his/her staff; the evaluation/selection committee; the mayor; and the city commission and their respective staff. The Cone of Silence shall be imposed when a formal competitive solicitation has been issued and shall remain in effect until an award is made, a contract is approved, or the Commission/Board of Directors takes any other action which ends the solicitation. Should any firm contact you, please direct the communication to the Procurement Department at (954) 457-1333.